

OFFICE USE ONLY
 Log No. 33247
 Permit No. _____
 Basin 8-103

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13441

PRINT OR TYPE ONLY

1. OWNER ANDRE BEAUPRE ADDRESS AT WELL LOCATION Unit 1 Lot 19 Dayton Nevada
 MAILING ADDRESS Dayton, Nevada
 2. LOCATION SE 1/4 NW 1/4 Sec. 30 T. 17 S. R. 22 E. STOREY County
 PERMIT NO. 2655 storey ch Issued by Water Resources Parcel No. _____ Subdivision Name MARK TWAIN ESTATES

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>OVERBURDEN</u> <u>WITH SEDIMENTARY</u> <u>Volcanic Basalt</u> <u>etc.</u>		0	7	7
<u>Sedimentary & Volcanic</u> <u>Materials, Cemented</u>		7	43	36
<u>Cemented Volcanic</u> <u>Scoria w/ clays,</u> <u>red to black</u> <u>fine to coarse</u> <u>grained</u>		36	237	201
<u>Granular to 1/4"</u> <u>Volcanic Material</u> <u>Carrying water</u>		237	275	38
<u>Cemented scoria</u>		275	280	5
<u>T.D. 280'</u>				

8. 10 3/4 WELL CONSTRUCTION
 Diameter 9 9/16 inches Total depth 280 feet
 _____ inches
 _____ inches
 Casing record 6 3/8" steel
 Weight per foot 11.7 Thickness 1 5/16

Diameter	From	To
<u>6 5/8</u> inches	<u>12</u> feet	<u>280</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 280 feet
 Perforations:
 Type perforation Factory Mill slot
 Size perforation 3/32" x 5"
 From 260 feet to 280 feet
 From _____ feet to _____ feet

Date started March 19, 1990
 Date completed March 19, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Gravel packed while develop-</u> <u>ing well with air</u> <u>Blew well for 4 hrs between</u> <u>2:30-2:75 Making 119 PM</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL
 Static water level 227 feet below land surface
 Flow 11 G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge
 Name A & H Pump Co Contractor
 Address Carson City, NV 89701 Contractor
 Nevada contractor's license number 23295 issued by the State Contractor's Board
 Nevada contractor's driller's number _____ issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources 1535
 Signed Jerald Phinnell By driller performing actual drilling on site or Contractor
 Date March 19, 1990