

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13723

1. OWNER ALLEN SCHADE ADDRESS AT WELL LOCATION 1550 Alicia Way
 MAILING ADDRESS 1980 Kings Row Reno, NV 89506
 Reno, NV 89503
 2. LOCATION SW 1/4 NW 1/4 Sec 35 T 21N N/S R 19 E Washoe County
 PERMIT NO. 076-110-01 Golden Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1 1/2	1 1/2
Weathered granite		1 1/2	9	8 1/2
Gray granite		9	40	31
Weathered granite with clay streaks		40	69	29
Gray hard granite		69	180	111
Fracture (NO WATER)		180	181	1
Gray hard granite		181	248	67
Soft zone (NO WATER)		248	249	1
Gray hard granite		249	271	22
Soft fracture (app 2GPM) X		271	273	2
Gray granite		273	314	41
Soft fracture (app 2GPM) X		314	315	1
Gray granite		315	371	56
Fracture X		371	372	1
GRAY granite		372	390	18
Fracture X		390	391	1
Gray granite		391	400	9

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 400 feet
 _____ inches
 _____ inches
 Casing record 400' steel casing installed
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6.5/8</u> inches	<u>0</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement grout, pumped
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 400 feet
 Perforations: factory sawed slot
 Type perforation _____
 Size perforation 3/32 x 3 x 5 around
 From 276 feet to 296 feet
 From 336 feet to 356 feet
 From 376 feet to 396 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 3-90, 19____
 Date completed 6-90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 220 feet below land surface
 Flow 20 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada contractor's driller's number 908 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 11, 1990