

OFFICE USE ONLY
 Log No. 33316
 Permit No. _____
 Basin 7-97

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12671

1. OWNER Washoe County ADDRESS AT WELL LOCATION Sand Pass
 MAILING ADDRESS P.O. Box 11130
Reno, NV 89520
 2. LOCATION SW 1/4 SW 1/4 Sec. 11 T. 27 N/S R. 19 E. Washoe County
 PERMIT NO. W-319 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE Monitor
 Domestic Irrigation 2" Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------------------|--------------|------|-----|------------|
| Silty sand | | 0 | 11 | 11 |
| Silty clay | | 11 | 39 | 28 |
| Yellow clay | | 39 | 105 | 66 |
| Red sandy clay | | 105 | 145 | 40 |
| Coarse sand & gravel | | 145 | 165 | 20 |
| Sandy clay | | 165 | 190 | 25 |
| Sand & clay stringers | | 190 | 231 | 41 |
| Sandy clay | | 231 | 250 | 19 |
| Sticky clay | | 250 | 285 | 35 |
| Fractured volcanic rock w/s clay | | 285 | 290 | 5 |
| Fractured basalt | | 290 | 480 | 190 |

APR 17 2:29 PM '90
 RECEIVED
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 8 inches Total depth 480 feet
 _____ inches
 _____ inches
 Casing record 2"
 Weight per foot _____ Thickness SCB 40 St

| Diameter | From | To |
|-----------------------|------|-----|
| 2" Blank _____ inches | 0 | 312 |
| 2" Perf _____ inches | 312 | 480 |
| _____ inches | | |

 Surface seal: Yes No Type Concrete
 Depth of seal 305 feet
 Gravel packed: Yes No
 Gravel packed from 305 feet to 480 feet
 Perforations:
 Type perforation Mill Slot
 Size perforation 1/8 - 2 1/2
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started March 5, 19 90
 Date completed March 8, 19 90

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL

Static water level _____ feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Contractor
 Address P.O. Box 592 Waca., NV 89445
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada contractor's driller's number issued by the Division of Water Resources C-23
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1449
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-12-90