WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33367
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14076

1. OWNER Mike Hickey Const.
MAILING ADDRESS Box 1420
Minden, NV 89423

ADDRESS AT WELL LOCATION
616 Frontage Rd.

2. LOCATION NE ¼ NW ¼ Sec 24 T 12 N/S R 20 E Douglas County
PERMIT NO. SW SW (Issued by Water Resources) | 29-050-13 (Parcel No.) | Hwy 395 South (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	7	7
Boulders w Cobbles		7	29	22
Gravels w/clay		29	52	23
Boulders w/clay		52	57	5
Gravels, Cemented		57	65	8
Boulders, clay Cement		65	88	23
Gravels with small 6" rock 2GPM	✓	88	105	17
Gravels w/Sand 6 GPM	✓	105	145	40
Gravels w/Sandy Clay	✓	145	170	
Major water from 160-170	new APN 1220-24-410			
TD 170 ft				

Date started 4/20, 1990
Date completed 4/25, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Gravel packed while flushing out mud. Developed with air blew 30 GPM from 160 feet for 3 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 170 feet
..... inches
..... inches
Casing record Steel 6 5/8
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	170 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 103 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 103 feet to 170 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 #3
From 150 feet to 170 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 62 feet below land surface
Flow 30 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kawchack Drilling Inc (Contractor)
Address Rt #3 2668 Fuller, Minden, NV 89423 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 021268
Nevada contractor's driller's number issued by the Division of Water Resources 1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1380
Signed Eddy S Kawchack
By driller performing actual drilling on site or contractor
Date 5/31/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627