WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33409
Permit No.
Basin 7-92b

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14933

1. OWNER CHESTER GOODELL
MAILING ADDRESS 11675 Heartpine
Reno, NV 89506

ADDRESS AT WELL LOCATION 11670 Heartpine
Reno, NV 89506

2. LOCATION NW ¼ SE ¼ Sec. 15 T. 21N N/S R. 19 E. Washoe County
PERMIT NO. ____ Issued by Water Resources; 80-362-10 Parcel No.; Lemmon Valley Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown sandy clay		3	18	15
Fine sand (NO WATER)		18	22	4
Brown sandy clay		22	60	38
Brown sands (NO WATER)		60	65	5
Brown sandy clay		65	82	17
Weathered granite		82	105	23
Gray granite		105	117	12
FrActure granite	X	117	122	5
Gray granite		122	129	7
Fracture granite	X	129	134	5
Gray granite		134	144	10
Fracture	X	144	146	2
GRay granite		146	150	4

Date started Moved rig on site 5-21-90, 19
Date completed 5-23-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 150 feet
____ inches
____ inches
Casing record 150' steel casing installed.
Weight per foot ____ Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 115 feet to 145 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 90 feet below land surface
Flow 35 G.P.M. ____ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. Contractor
Address P.O. Box 12370, Reno, NV 89510 Contractor
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] By driller performing actual drilling on site or contractor
Date May 24, 1990

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627