WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33410
Permit No.
Basin 7-92b

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14932

1. OWNER: BRADY BITZ
MAILING ADDRESS: 10 East L Street, Sparks, NV 89431
ADDRESS AT WELL LOCATION: 221 Oregon Blvd., Reno, NV 89506

2. LOCATION: SW ¼ SW ¼ Sec. 15 T. 21N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 80-324-03 (Parcel No.) Lemmon Valley (Subdivision Name)

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	67	66
Soft zone		67	69	2
Brown clay		69	91	22
Soft zone brown sand		91	99	8
BRown clay		99	116	17
BRown sand		116	122	6
BRown clay		122	124	2
Soft zone	X	124	138	14
BRown clay		138	140	2
Soft zone	X	140	154	14
Brown sandy clay		154	155	1
Fine brown sand		155	158	3

Date started 5-24-90, 19
Date completed 5-25-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 158 feet
inches
inches
Casing record 158' steel casing installed.
Weight per foot ..... Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	158 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 51 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 51 feet to 158 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 120 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 98 feet below land surface
Flow 9.375 G.P.M. ..... P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date May 31, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627