WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33460
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3372

1. OWNER JOHN WEISSER
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SW ¼ Sec. 35 T. 19S N/S R. 52 E. NYE County
PERMIT NO. (Issued by Water Resources) Parcel No. OLD SPANISH TRAILS RANCHOES (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	2'	2'
calichie		2'	3'	1'
clay		3'	8'	5'
calichie		8'	10'	2'
clay		10'	24'	14'
calichie		24'	27'	3'
clay		27'	37'	10'
calichie		37'	38'	1'
clay		38'	45'	7'
calichie		45'	48'	3'
clay		48'	56'	8'
calichie	WB	56'	63'	7'
clay		63'	66'	3'
calichie	WB	66'	67'	1'
clay		67'	77'	10'
calichie	WB	77'	78'	1'
clay		78'	81'	3'
calichie	WB	81'	83'	2'
clay		83'	89'	6'
calichie	WB	89'	94'	5'
clay		94'	97'	3'
calichie	WB	97'	99'	2'
clay		99'	106'	7'
calichie	WB	106'	109'	3'
clay		109'	111'	2'
sand & gravel	WB	111'	140'	29'

Date started 5-5, 1990
Date completed 5-8, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
MAY 29 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140' feet
inches
inches
Casing record 140' X 8 5/8"
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation factory sawcut
Size perforation 1/8" x 3"
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 42 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S&H DRILLING (Contractor)
Address HCR 65 box 80358 PAHRUMP, NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 5-18-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627