WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33480
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3784

1. OWNER FRED SCHULTZ
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 32 T. 19 S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) Lot 3 (Parcel No.) UNIT 6 RANCHO DEL-SOL (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	18	18
CALICHIE		18	20	2
CLAY		20	31	11
CALICHIE		31	33	2
CLAY		33	56	23
CALICHIE	WB	56	60	4
CLAY		60	73	13
CALICHIE	WB	73	75	2
CLAY		75	90	2.5
CALICHIE	WB	90	92	2
CLAY		92	98	6
CALICHIE	WB	98	101	3
CLAY		101	129	28
CALICHIE	WB	129	134	5
CLAY		134	140	6

RECEIVED JAN 23 1990 Div. of Water Resources Branch Office - Las Vegas NV

Date started 1-10, 1990
Date completed 1-15, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 1/4 inches Total depth 140 feet
inches
inches
Casing record 140' 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 INCH BY 3 INCH
From 140 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S+H Drilling (Contractor)
Address HCR 65 Box 70906 Pahrump NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Donnie Brown (By driller performing actual drilling on site or contractor)
Date 1-18-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627