WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33497
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5209

1. OWNER Millard Sloan
MAILING ADDRESS 6880 N. Rainbow
Las Vegas, Nv. 89131

ADDRESS AT WELL LOCATION Deer Springs & Rainbow

2. LOCATION NE ¼ NE ¼ Sec. 22 T. 19 N/S R. 60 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & Silt | | 0 | 21 | 21 |
| Tan Clay | | 21 | 117 | 96 |
| Red Clay | | 117 | 247 | 130 |
| Tan Clay | | 247 | 295 | 48 |
| Tan Clay & Wash Rock | x | 295 | 311 | 16 |
| Tan Rock | xx | 311 | 445 | 134 |

RECEIVED
JUN 06 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 15, 19 90
Date completed May 22, 19 90

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Air | 40 | 7 | 1 |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10" inches Total depth 445 feet
inches
inches
Casing record 6 5/8"
Weight per foot ..... Thickness .....

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 445 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☐ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation 1/16 x 6"
From 245 feet to 445 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 127 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0018916
Nevada contractor's driller's number issued by the Division of Water Resources 1301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
Signed Fred B. Allen
By driller performing actual drilling on site or contractor
Date .....

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627