WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33506
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3530

1. OWNER HaROLD Goodrich
MAILING ADDRESS 533 No. Lamb, Apt. 3
Las Vegas, NV 89110

ADDRESS AT WELL LOCATION
6015 Moonlight Dr.

2. LOCATION SW ¼ NE ¼ Sec. 27 T. 19 N/S R. 60 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & gravel		0	100	100
Cemented gravel		100	260	160
Clay & gravel		260	320	60
Cemented gravel		320	405	85
Sand, cem. grav., alluvial		405	420	15
405 Clay, sand, cem. grav.		420	465	45
Red clay, unconsolidated grav		465	500	35

RECEIVED
FEB 9 1997
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started October 9, 19 89
Date completed November 20, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 3/4 inches Total depth 500 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .156

Diameter	From	To
8 inches	+1 feet	500 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 500 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2½" 8 rows
From 360 feet to 420 feet
From 440 feet to 460 feet
From 480 feet to 500 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 220 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC.
Contractor
Address 4185 W. Harmon Las Vegas, NV 89103
Contractor
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources the on-site driller 561
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date November 21, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627