



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. **3785**

PRINT OR TYPE ONLY

1. OWNER **ELIZABETH COLEMAN** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION **SE 1/4 SW 1/4 Sec 9 T 20S N15R 53 E NYE** County
 PERMIT NO. **66711** Parcel No. **UNIT D CAL-VEGAS RANCHOS** Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	6	6
CALICHE		6	8	2
CLAY		8	52	44
CALICHE	W.B.	52	55	3
CLAY		55	61	6
CALICHE	W.B.	61	66	5
CLAY		66	76	10
CALICHE	W.B.	76	77	1
CLAY		77	81	4
CALICHE	W.B.	81	87	8
CLAY		87	106	17
CALICHE	W.B.	106	109	3
CLAY		109	120	11
CALICHE	W.B.	120	121	1
CLAY		121	132	11
CALICHE	W.B.	132	134	2
CLAY		134	140	6

RECEIVED
 JAN 23 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
 Diameter **12 1/4** inches Total depth **140** feet
 _____ inches
 _____ inches
 Casing record **140 8 5/8 OD**
 Weight per foot **14.11** Thickness **.156**

Diameter	From	To
8 5/8 inches	0 feet	140 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type **CONCRETE**
 Depth of seal **50** feet
 Gravel packed: Yes No
 Gravel packed from **140** feet to **50** feet
 Perforations:
 Type perforation **FACTORY SAW CUT**
 Size perforation **3 INCH BY 3 INCH**
 From **140** feet to **120** feet
 From _____ feet to _____ feet

Date started **1-10**, 19**90**
 Date completed **1-15**, 19**90**

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level **42** feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature **66.5** °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **S & H DRILLING** Contractor
 Address **HCR 65 BOX 70906 PAHRUMP NV 89041** Contractor
 Nevada contractor's license number issued by the State Contractor's Board **22059**
 Nevada contractor's driller's number issued by the Division of Water Resources **1426**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1573**
 Signed **Donnie Brown**
 By driller performing actual drilling on site or contractor
 Date **1-18-90**

