


Log No. **33541**

Permit No. _____

Basin. **162**



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. **3887**

PRINT OR TYPE ONLY

1. OWNER RICHARD ZISLER ADDRESS AT WELL LOCATION BRIAN
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NW 1/4 Sec. 11 T. 20S N/S R. 53 E NYE County _____

PERMIT NO. _____ lot 15 Parcel No. _____ RED ROCK ESTATES Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	7'	7'
caliche		7'	9'	2'
clay		9'	28'	19'
caliche		28'	31'	3'
clay		31'	36'	5'
caliche		36'	38'	2'
clay		38'	43'	5'
caliche		43'	44'	1'
clay		44'	56'	12'
caliche	tr	56'	58'	2'
clay		58'	61'	3'
caliche	WB	61'	62'	1'
clay		62'	76'	14'
caliche	WB	76'	77'	1'
clay		77'	81'	4'
caliche	WB	81'	86'	5'
clay		86'	95'	9'
caliche	WB	95'	96'	1'
clay		96'	112'	16'
caliche	WB	112'	113'	1'
clay		113'	118'	5'
caliche	WB	118'	119'	1'
clay		119'	126'	7'
caliche	WB	126'	128'	2'
clay		128'	134'	6'
caliche	WB	134'	140'	6'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140' by 8 5/8"
 Weight per foot 14.11 Thickness 156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140' feet to 50' feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" by 3"
 From 140' feet to 120' feet
 From _____ feet to _____ feet

Date started 4-22, 1990
 Date completed 4-24, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 5' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S&H DRILLING Contractor
 Address HCR 65 box 80358 PAHRUMP, NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22059
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 4-24-90

Div. of Water Resources
 Branch Office - Las Vegas
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

