



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. **3864**

PRINT OR TYPE ONLY

1. OWNER HAL FINCHER ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SW 1/4 Sec 18 T 20S N/S R 53 E NYE County _____
 PERMIT NO. _____ CHARLESTON PARK RANCHOES Unit 5 lot 45
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	5'	5'
caliche		5'	6'	1'
clay		6'	18'	12'
caliche		18'	20'	2'
clay		20'	36'	16'
caliche		36'	37'	1'
clay		37'	54'	17'
caliche	WB	54'	55'	1'
clay		55'	63'	8'
caliche	WB	63'	65'	2'
clay		65'	72'	7'
caliche	WB	72'	73'	1'
clay		73'	78'	5'
caliche	WB	78'	79'	1'
clay		79'	84'	5'
caliche	WB	84'	86'	2'
clay		86'	92'	6'
caliche	WB	92'	94'	2'
clay		94'	102'	8'
caliche	WB	102'	105'	3'
clay		105'	120'	15'
caliche	WB	120'	121'	1'
clay		121'	132'	11'
caliche	WB	132'	136'	4'
clay		136'	140'	4'

8. WELL CONSTRUCTION
 Diameter 12 1/4 inches Total depth 140 feet
 _____ inches
 _____ inches
 Casing record 140' X 8 5/8"
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1 7/8" X 3"
 From 140 feet to 80 feet
 From _____ feet to _____ feet

Date started 5-11 1990
 Date completed 5-27 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Div. of Water Resources
 Branch Office - Las Vegas, NV

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 42 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S&H DRILLING Contractor
 Address HCR 65 box 80358 PAHRUMP, NV 89041
 Nevada contractor's license number 22059 issued by the State Contractor's Board.
 Nevada contractor's driller's number 1426 issued by the Division of Water Resources.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Donnie Brown
 By driller performing actual drilling on site or contractor
 Date 5-22-90

