

Log No. 33600

Permit No. Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7036

PRINT OR TYPE ONLY

1. OWNER ROBERT SWARTZ ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SW 1/4 Sec. 1 T. 21S N/S R. 53 E NYE County
 PERMIT NO. _____ LOT 195 MANCO SUBDIVISION
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------|--------------|------|------|-----------|
| clay | | 0' | 6' | 6' |
| caliche | | 6' | 7' | 1' |
| clay | | 7' | 17' | 10' |
| caliche | | 17' | 18' | 1' |
| clay | | 18' | 22' | 4' |
| caliche | | 22' | 25' | 3' |
| clay | | 25' | 41' | 16' |
| caliche | | 41' | 44' | 3' |
| clay | | 44' | 52' | 8' |
| caliche | | 52' | 53' | 1' |
| clay | | 53' | 64' | 11' |
| caliche | WB | 64' | 66' | 2' |
| clay | | 66' | 78' | 12' |
| caliche | WB | 78' | 81' | 3' |
| clay | | 81' | 84' | 3' |
| caliche | WB | 84' | 85' | 1' |
| clay | | 85' | 89' | 4' |
| caliche | WB | 89' | 91' | 2' |
| clay | | 91' | 97' | 6' |
| caliche | WB | 97' | 101' | 4' |
| clay | | 101' | 116' | 15' |
| caliche | WB | 116' | 117' | 1' |
| clay | | 117' | 121' | 4' |
| caliche | WB | 121' | 123' | 2' |
| clay | | 123' | 128' | 5' |
| caliche | WB | 128' | 131' | 3' |
| clay | | 131' | 135' | 4' |
| caliche | WB | 135' | 140' | 5' |

Date started 5-21-1990
 Date completed 5-24-1990

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140' X 8 5/8"
 Weight per foot 14.11 Thickness .156
 Diameter From To
8 5/8 inches 0 feet 140 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" x 3"
 From 140 feet to 120 feet
 From _____ feet to _____ feet

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 52 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S&H DRILLING
 Address HCR 65 box 80358 PAHRUMP, NEVADA
Contractor Contractor
 Nevada contractor's license number 89041
 issued by the State Contractor's Board 22059
 Nevada contractor's driller's number 1426
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
By driller performing actual drilling on site or contractor
 Date 5-24-90

Div. of Water Resources
 BAILER TEST
 Branch Office - Las Vegas, NV

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

RECEIVED
 MAY 29 1990