

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 3870

PRINT OR TYPE ONLY

1. OWNER GORDEN HANON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION NE 1/4 NE 1/4 Sec 10 T. 21S N/S R. 53 E. NYE County
 PERMIT NO. _____ lot 5 PLANTATION ESTATES block 8
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	9'	9'
calichie		9'	10'	1'
clay		10'	26'	16'
calichie		26'	27'	1'
clay		27'	43'	16'
calichie		43'	44'	1'
clay		44'	56'	12'
calichie	WB	56'	57'	1'
clay		57'	66'	9'
calichie	WB	66'	67'	1'
clay		67'	88'	21'
calichie	WB	88'	90'	2'
clay		90'	104'	14'
calichie	WB	104'	107'	3'
clay		107'	121'	14'
calichie	WB	121'	125'	4'
clay		125'	130'	5'
calichie	WB	130'	133'	3'
clay		133'	136'	3'
calichie	WB	136'	137'	1'
clay		137'	140'	3'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140' X 8 5/8"
 Weight per foot 14.11 Thickness 156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140' feet to 50' feet
 Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" X 3"
 From 140 feet to 120 feet
 From _____ feet to _____ feet

RECEIVED
 MAY 23 1990
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 5-7, 1990
 Date completed 5-11, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED
 MAY 23 1990
 BAILER TEST

G.P.M. _____ feet _____ hours
 G.P.M. _____ feet _____ hours
 G.P.M. _____ feet _____ hours

9. WATER LEVEL
 Static water level 50 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S&H DRILLING
 Contractor
 Address HCR. 65 box 80358 PAHRUMP, NV 89041
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22059
 Nevada contractor's driller's number issued by the Division of Water Resources 1426
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-18-90

