

OFFICE USE ONLY
 Log No. 93630
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 3701

WELL DRILLER'S REPORT

Please complete this form in its entirety

1 1/2 book

PRINT OR TYPE ONLY

1. OWNER BOB MADSON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NE 1/4 Sec 19 T 21S N/S R 54 E NYE County
 PERMIT NO. _____ LOT 705 GREEN SADDLE RANCH
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	10'	10'
caliche		10'	12'	2'
clay		12'	25'	13'
caliche		25'	27'	2'
clay		27'	37'	10'
caliche		37'	38'	1'
clay		38'	43'	5'
caliche		43'	45'	2'
clay		45'	54'	9'
caliche	WB	54'	55'	1'
clay		55'	59'	4'
caliche	WB	59'	63'	4'
clay		63'	84'	21'
caliche	WB	84'	86'	2'
clay		86'	89'	3'
caliche	WB	89'	93'	4'
clay		93'	105'	12'
caliche	WB	105'	108'	3'
clay		108'	117'	9'
caliche	WB	117'	118'	1'
clay		118'	120'	2'
caliche	WB	120'	122'	2'
clay		122'	125'	3'
caliche	WB	125'	134'	9'
clay		134'	140'	6'

8. WELL CONSTRUCTION
 Diameter 12 1/2 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140' X 8 5/8"
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>8 5/8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140' feet to 50' feet
 Perforations: factory sawcut
 Type perforation _____
 Size perforation 1/8" X 3"
 From 140' feet to 120' feet
 From _____ feet to _____ feet

Date started 4-13 1990
 Date completed 4-18 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 4.8 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S&H Drilling
 Address HCR 65 box 80358 PAHRUMP, NV 89041
 Nevada contractor's license number 22059
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1426
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed Donnie Brown
 By driller performing actual drilling on site or contractor
 Date 5-9-90

RECEIVED
 MAY 11 1990

