WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 33631
Permit No.
Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3796

1. OWNER TOM FLORES
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 19 T. 21 S N/S R. 54 E. NYE County
PERMIT NO. (Issued by Water Resources) 252 (Parcel No.) GREEN SADDLE RANCH (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	11	11
CALICHIE		11	12	1
CLAY		12	35	23
CALICHIE		35	38	3
CLAY		38	43	5
CALICHIE		43	45	2
CLAY		45	54	9
CALICHIE	TS	54	57	3
CLAY		57	70	13
CALICHIE	WB	70	72	2
CLAY		72	77	5
CALICHIE	WB	77	78	1
CLAY		78	84	6
CALICHIE	WB	84	88	4
CLAY		88	95	7
CALICHIE	WB	95	96	1
CLAY		96	106	10
CALICHIE	WB	106	108	2
CLAY		108	113	5
CALICHIE	WB	113	119	6
CLAY		119	124	5
CALICHIE	WB	124	127	3
CLAY		127	135	8
GRAVEL	WB	135	140	5

Date started 2-9, 19 90
Date completed 2-12, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

RECEIVED FEB 28 1990 Div. of Water Resources Branch Office: Las Vegas, NV

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 12 ¼ inches Total depth 140 feet
inches
inches
Casing record 140 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 52 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S & H DRILLING (Contractor)
Address HCR 65 BOX 70906 PAHRUMP NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-19-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627