WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33652
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6015

1. OWNER CLARK CO. DEPT. AVIATION
MAILING ADDRESS P.O. BOX 11005 - AIRPORT STA. LAS VEGAS, NV 89111-1005
ADDRESS AT WELL LOCATION FORMER ELARDI SITE HACIENDA & SWENSON LAS VEGAS, NV

2. LOCATION NW ¼ SW ¼ Sec. 27 T. 21 N/S R. 61 E CLARK County
PERMIT NO. MO 2026 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE MONITOR ☒: Domestic ☐ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	7	7
CEMENTED SAND & GRAVEL		7	8	1
SAND & GRAVEL, CLAY		8	12	4
CEMENTED SAND & GRAVEL		12	17	5
CLAY		17	23	6
SAND		23	25	2
CALICHE		25	30	5
CLAY		30	35	5

RECEIVED
JAN 19 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started JULY 19, 1989
Date completed JULY 19, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. N/A Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 35 feet
____ inches
____ inches BORING M-4
Casing record
Weight per foot PVC Thickness SCH 40

Diameter	From	To
2 inches	0 feet	35 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT/BENT. GROUT
Depth of seal 0-11 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 11 - 35 feet to ____ feet

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.020"
From 15 feet to 35 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 23.0 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON C/O CONVERSE CONSULTANTS (Contractor)
Address 4670 S. POLARIS LV, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/8/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627