

Doc No. 33663  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 3535

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Pete Carollo ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 6660 Raven Las Vegas, NV 89118  
 2. LOCATION NE 1/4 NW 1/4 Sec 23 T. 22 R. 60 E. Clark County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Caliche		0	14	14
Cemented gravel		14	20	6
Sand & gravel, boulders cemented layers		20	100	80
Cemented gravel, hard rock		100	140	40
Sand, gravel, some clay		140	235	95
Cemented gravel & sand		235	280	45
Sand, gravel, clay		280	320	40
Cemented		320	400	80
Sand, gravel, clay		400	440	40
Red sandstone, part. cem.		440	565	125
Cemented gravel		565	580	15
Sand & gravel		580	660	80

8. WELL CONSTRUCTION  
 Diameter 12 3/4 inches Total depth 660 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness .156  

Diameter	From	To
<u>8</u> inches	<u>+1</u> feet	<u>660</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 51 feet  
 Gravel packed: Yes  No   
 Gravel packed from 51 feet to 660 feet  
 Perforations:  
 Type perforation Mill cut  
 Size perforation 1/8 x 2 5/8"  
 From 515 feet to 536 feet  
 From 556 feet to 619 feet  
 From 639 feet to 660 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 FEB 9 1997  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started November 22, 1989  
 Date completed December 5, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 413 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name THOMPSON DRILLING CO., INC.  
4185 W. Harmon Contractor  
 Address Las Vegas, NV 89103 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 4286A  
 Nevada contractor's driller's number issued by the Division of Water Resources 290  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 561  
 Signed Richard K. Thompson  
 By driller performing actual drilling on site or contractor  
 Date February 7, 1990