

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 2515

PRINT OR TYPE ONLY

1. OWNER DON DEEMER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 SE 1/4 Sec. 24 T. 22 N/S R. 60 E. CLARK County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
LOOSE GRAVEL		0	6	
CEMENTED GRAVEL		6	11	
GRAVEL & SAND		11	280	
HARD CEMENTED GRAVEL		280	285	
GRAVEL & SAND		285	310	
GRAVEL & WATER		310	325	
GRAVEL & SAND		325	340	
GRAVEL & WATER		340	355	
HARD CEMENTED GRAVEL		355	400	
GRAVEL CLAY & WATER		400	430	
HARD CEMENTED GRAVEL		430	458	

**RECEIVED**  
 FEB 22 1990

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started Jan 29, 1990, 19\_\_\_\_  
 Date completed Feb 6, 1990, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 458 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness \_\_\_\_\_  
 Diameter From To 156  
8 5/8 inches \_\_\_\_\_ feet 458 feet  
 \_\_\_\_\_ inches +1 feet \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet

Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal X \_\_\_\_\_ CEMENT feet  
 Gravel packed: 60  No   
 Gravel packed from \_\_\_\_\_ X feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation FACTORY  
 From \_\_\_\_\_ 3/16" to X 6 ROW feet  
 From 418 feet to 438 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 255 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VERNON H. DUMICK  
 Address 7115 ROGERS LV NV 89118  
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10062

Nevada contractor's driller's number issued by the Division of Water Resources 552

Nevada driller's license number issued by the Division of Water Resources; the on-site driller 552

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date 2-20-90