

OFFICE USE ONLY
 Log No. 33695
 Permit No. _____
 Basin 8-1051

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 15206

PRINT OR TYPE ONLY

1. OWNER DEAN ERWIN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1102 Leonard 1663 Windmill
GARDNERVILLE, NEVADA Gardnerville, Nevada
 2. LOCATION SW 1/4 SK NW 1/4 Sec. 33 T. 13 N/S R. 21 E. Douglas County
 PERMIT NO. N one 23-160-19 None
Issued by Water Resources Parcel No. (NEW APN # 1321-33-001-021) Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Set up over well and ran bit to bottom.				
Encountered mud and fill at 98 feet.				
Static level of water at this time was 82 feet.				
Flushed mud and detrital from annulus and tagged bottom of bore hole at 112 feet.				
Worked tools in casing from 100 to 112 feet until a stable flow return came from well.				
Static level in well after reconditioning 75 feet, with a production flow of 22 gpm.				
T.D. 112 feet				
See: Log # 8932				
deepened by well log # 111468				
		38.950, 061° N	MADDP	
		119.638, 62.5° W	D.D.	

Date started May 14, 1990
 Date completed May 15, 1990

8. WELL CONSTRUCTION

Diameter Unknown inches Total depth 112 feet

Casing record 8 5/8"
 Weight per foot 13.7 Thickness .156

Diameter	From	To
<u>8 5/8</u> inches	<u>1</u> feet	<u>112</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Concrete
 Depth of seal Unknown feet
 Gravel packed: Yes No Unknown
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Unknown No log on file
 Size perforation Unknown

From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 75 feet below land surface
 Flow 22 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO.
 Address CARSON CITY, NEVADA
Contractor
Contractor

Nevada contractor's license number issued by the State Contractor's Board 23295
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1674
 Signed Joe Butts
By driller performing actual drilling on site or contractor
 Date 5/15/90 mmH (F)

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours