WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33719
Permit No.
Basin G-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14916

1. OWNER BRIAN SANDERS
MAILING ADDRESS 275 Gleeson Way
Sparks, NV 8943

ADDRESS AT WELL LOCATION West View Cir.
Sparks, NV

2. LOCATION NW ¼ NW ¼ Sec 1 T 19N N/S R 20 E WAshoe County
PERMIT NO. (Issued by Water Resources) 030-184-01 (Parcel No.) East Sparks, (Sparks Fam Hosp.area) (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Multi-color clays		1	80	79
Black volcanic rock		80	130	50
Soft zone	X	130	140	10
Soft volcanic rock with clay streaks		140	160	20
Brown volcanic rock		160	225	65
Soft zone	X	225	230	5
BRown volcanic rock		230	297	67
Soft zone	X	297	305	8
BRown volcanic rock		305	311	6
GReen volcanic rock		311	325	24

'90 JUN 20 10:02
STATE ENGINEER

Date started 6-13-90, 19
Date completed 6-15-90, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 325 feet
inches
inches
Casing record 325' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	325 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 325 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 119 feet to 139 feet
From 219 feet to 239 feet
From 299 feet to 319 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 127 feet below land surface
Flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, REno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date June 18, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627