

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 15663

PRINT OR TYPE ONLY

1. OWNER Don Woelfle ADDRESS AT WELL LOCATION 2330 Derbish Way
 MAILING ADDRESS 455 Crampton Parcel 1 of Map 726
Ren o, Nv 89502

2. LOCATION SE 1/4 SW 1/4 Sec. 21 T 19 N/S R. 20 E Washoe County _____
 PERMIT NO. 021-131-40

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	14	14
Blue Clay		14	22	8
Multi-colored course sands w/ blue clay & fine sands		22	42	20
Cobbles & boulders		42	80	38
Multi-colored coarse sands & fine brown sand with trace brown clay		80	89	9
Gray clay w/multi-colored coarse sands with fine brown sand		89	100	11
Black yellow white green coarse sands w/ gray clay		100	118	18
Black white green red coarse sand & fine green sand	X	118	136	18
Gray clay		136	140	4
T.D. 136 ft				
A 1/8" steel plate on bottom				

8. WELL CONSTRUCTION

Diameter 11 inches Total depth 136 feet

Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1</u> feet	<u>136</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 136 feet

Perforations:
 Type perforation screen
 Size perforation .030
 From 120 feet to 130 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 5/7/90 19____
 Date completed 5/9/90 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>30</u>	<u>STA</u>		

Blew with air to clean and develop.

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 4 feet below land surface
 Flow 20+ G.P.M. P.S.I. _____
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L Sparks, Nv
 Contractor 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132
 issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor

Date Roger M. Thrall 5/10/90