

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 15861

PRINT OR TYPE ONLY

1. OWNER Texaso ADDRESS AT WELL LOCATION Texaso  
 MAILING ADDRESS 3015 Broadway Rd 1400 Mayberry  
Salem, Ore, 95327 Kenia, Nevada 89409  
 2. LOCATION NW 1/4 SE 1/4 Sec 15 T. 17N N/S.R. 19E E. Washoe County  
 PERMIT NO. M-9267 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name Texaso Gas Station

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other  Percussion

6. LITHOLOGIC LOG B-2

Material	Water Strata	From	To	Thick-ness
Asphalt Pavement		0	0.5	0.5
Green Silty Gravel		0.5	3.5	3.0
Gray gravelly sand		3.5	7.5	4.0
Brown gravel		7.5	16.5	9.0
Lt. gray rock (granite)		16.5	18.5	2.0
Brown sandy silt		18.5	<del>22</del> 22	3.5
Brown sandy gravel		22	24	2.0
Brown clayey silt		24	30	6.0
Tan/brown clay w/ sand & gravel		30	33.5	3.5
Brown gravel and cobbles		33.5	60	26.5
Brown silty sand w/ gravels		60	65	5.0

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 65 feet  
Borehole inches  
 Casing record SCH 40 PVC  
 Weight per foot \_\_\_\_\_ Thickness \_\_\_\_\_  
 Diameter From To  
4 inches 0 feet 65 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type 9.5" SAK  
 Depth of seal 41 feet  
 Gravel packed: Yes  No   
 Gravel packed from 41 feet to 65 feet  
 Perforations:  
 Type perforation slot  
 Size perforation .020 inch  
 From 45 feet to 65 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started June 25, 1990  
 Date completed June 26, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Not performed</u>			

BAILER TEST  
 G.P.M. Not performed Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Layne Environmental Contractor  
 Address No 15 Valley Blvd Fortuna Ca Contractor 92335  
 Nevada contractor's license number issued by the State Contractor's Board 0019101  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources / on-site driller 1468  
 Signed Stephen Brown By driller performing actual drilling on site or contractor  
 Date July 11, 1990