

OFFICE USE ONLY  
 Log No. 33859  
 Permit No. \_\_\_\_\_  
 Basin 5775 Brady's Hot Spr.

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 5795

PRINT OR TYPE ONLY

OWNER Gilroy Foods ADDRESS AT WELL LOCATION Brady Hot Springs  
 MAILING ADDRESS PO Box 1088 Geothermal Food Processors  
Gilroy CA 95021-1088  
 2. LOCATION SE 1/4 NE 1/4 Sec. 12 T. 22 N35 R. 26 E Churchill County  
 PERMIT NO. 44647 NW  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay, gravel + silt		0	88	
Basalt		88	132	
ss.		132	140	
Basalt		140	148	
Clay + shale		148	183	
Basalt		183	240	
Clay		240	270	
Basalt		270	285	
Clay		285	297	
Basalt		297	305	
Clay (green)		305	342	
Basalt		342	354	
green/Br. sd	✓	354	385	
Basalt		385	395	
Clay		395	460	
Basalt - some clays		460	650	
interbedded clays in Basalt		650	1087	

8. WELL CONSTRUCTION  
 Diameter hole 1.7 1/2 inches Total depth 1078 feet  
 Casing record 16" to 119 12 3/4" to 271  
 Weight per foot 65 Thickness 330  

Diameter	From	To
<u>1.6</u> inches	<u>0</u> feet	<u>119</u> feet
<u>1.2 3/4</u> inches	<u>119</u> feet	<u>600</u> feet
<u>1.2 1/2</u> inches	<u>600</u> feet	<u>687</u> feet
<u>8 1/2</u> inches	<u>687</u> feet	<u>1078</u> feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 277 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations: N/A  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 20 feet below land surface  
 Flow 020 G.P.M. 25 P.S.I.  
 Water temperature 20.4 ° F. Quality \_\_\_\_\_

Date started 3-11 1986  
 Date completed 4-19 1986

7. N/A WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Waytek Drilling Co. Contractor  
 Address 4662 MAYNARD Sparks NV. Contractor  
 Nevada contractor's license number 19157  
 Nevada contractor's drillers number 1374  
 Nevada driller's license number 1442 / 1374 Actual Driller  
 Signed Les Waytel Contractor  
 Date 5-15-86

N/A BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours