

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 14922

PRINT OR TYPE ONLY

1. OWNER Newmont Gold CO ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 667 \_\_\_\_\_  
 2. LOCATION NW 1/4 SE 1/4 Sec 31 T. 36 N N/S R. 50 E Fureka County \_\_\_\_\_  
 PERMIT NO. MO-154223 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  LC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Siltstone</u>		<u>0</u>	<u>245</u>	<u>245</u>
<u>Intrusive</u>	<u>X2</u>	<u>245</u>	<u>300</u>	<u>55</u>
<u>Intrusive</u>		<u>245</u>	<u>300</u>	<u>55</u>
<u>Siltstone</u>		<u>300</u>	<u>330</u>	<u>30</u>
<u>Norm fels</u>		<u>330</u>	<u>390</u>	<u>60</u>
<u>Clay</u>		<u>390</u>	<u>410</u>	<u>20</u>
<u>Norm fels</u>		<u>410</u>	<u>430</u>	<u>20</u>
<u>Clay</u>		<u>430</u>	<u>500</u>	<u>70</u>

190 JUL -6 AM 10:00  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 5 3/4 inches Total depth 505 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches

Casing record \_\_\_\_\_  
 Weight per foot 19 lbs Thickness 1/4

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>20</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 505 feet to 460 feet  
can 1 1/4 PVC to 500' 40' screens on bottom

Perforations: on bottom  
 Type perforation slots  
 Size perforation \_\_\_\_\_  
 From 500 feet to 460 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-15 1990  
 Date completed 5-19 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 145 feet below land surface  
 Flow 15 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 65 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kimrock Drill 149 Contractor  
 Address P.O. Box 816 ELKO NV Contractor

Nevada contractor's license number issued by the State Contractor's Board 0022708  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1670  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5-19-90