DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

33951
OFFICE USE ONLY
Log No. 33951
Permit No.
Basin 212

# WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER ALTON C BINGHAM ADDRESS 6411 W DEER SPRINGS WAY LAS VEGAS NEVADA

2. LOCATION NE ¼ SW ¼ Sec. 23 T. 19 N/S R. 60 E. CLARK County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SOIL | | 0 | 2 | 2 |
| WHITE CLAY | 85 | 2 | 85 | 83 |
| RED CLAY & ROCK | | 85 | 186 | 101 |
| RED CLAY | | 186 | 230 | 44 |
| RED CLAY ROCK | | 230 | 260 | 30 |
| CALICHE | | 260 | 275 | 15 |
| LIME ROCK | | 275 | 285 | 10 |
| RED CLAY & ROCK | | 285 | 325 | 40 |
| CALICHE | | 325 | 345 | 20 |
| RED CLAY | | 345 | 370 | 30 |
| RED CLAY AND ROCK | | 370 | 400 | 30 |

RECEIVED
SEP 07 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started ....., 19....
Date completed 6-13-79, 19....

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST no test
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 14" inches Total depth 400 feet
Casing record 8"
Weight per foot ..... Thickness 10 GAG

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 400 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 900' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 200' feet to 400 feet

Perforations:
Type perforation Sawed ⅛ x 3"
Size perforation ⅛ x 3
From 287 feet to 400 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 65 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Grant W Cox
Address 890 E. 900 So.
Nevada contractor's license number 10015-A
Nevada driller's license number 564
Signed Grant W Cox
Date 6-18-79

USE ADDITIONAL SHEETS IF NECESSARY

5471

H. Bruce Cox
6511 Deer Spring Way
Las Vegas, Nev 89131

RE: Permit No. 50369

Well log 59954 belongs to Permit No. 50369. (I helped set up the drill rig.)

Well Log 33951(?) that is in the File for Permit No. 50369 was actually drilled for Alton Clark Bingham at the street address shown on well Log 33951 (6411 W. Deer springs way).

Grant W. Cox and Norris Cox are brothers - Cousins of mine.

H Bruce Cox
(702) 656-0172

Updated in wlog,
DSB

01/05/2016 by DSB