

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8537

PRINT OR TYPE ONLY

1. OWNER Gene Baker ADDRESS AT WELL LOCATION Vickie Ann
 MAILING ADDRESS _____ Pahrump, Nv 89041

2. LOCATION NW $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 1 T. 21S N/S R. 53 E. NYE County
 PERMIT NO. n/a Issued by Water Resources Parcel No. 44-011-10 Subdivision Name _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	6'	6'
caliche		6'	10'	4'
clay		10'	36'	26'
caliche		36'	42'	6'
clay		42'	60'	18'
caliche	WB	60'	64'	4'
clay		64'	83'	19'
caliche	WB	83'	89'	6'
clay		89'	105'	16'
caliche	WB	105'	111'	6'
clay		111'	123'	12'
caliche	WB	123'	137'	14'
clay		137'	140'	3'

8. WELL CONSTRUCTION

Diameter 12 1/2 inches Total depth 140' feet
 _____ inches
 _____ inches
 Casing record 140' x 8 5/8"
 Weight per foot 14.11 Thickness 15.6
 Diameter From To
8 5/8 inches 0 feet 140 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type concrete
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 140 feet to 50 feet

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8" x 3"
 From 140 feet to 120 feet
 From _____ feet to _____ feet

RECEIVED

AUG 30 1990

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 8-5, 1990
 Date completed 8-7, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 41' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING
 Contractor
 Address HCR 65 Box 80358 Pahrump, NV 89041
 Contractor
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1426
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller _____
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-22-90