WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35008
Permit No.
Basin 5-76

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER JUNE ENHELDER
MAILING ADDRESS ROUTE 1 Box 397
FERNLEY, NV. 89408

ADDRESS AT WELL LOCATION SAME AS MAILING ADDRESS

2. LOCATION NE ¼ SE ¼ Sec. 13 T. 20 N S R. 24 E LYON County
PERMIT NO. Issued by Water Resources | Parcel No. 21-111-10 | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
THIS LOG IS FOR PLUGGING OF OLD WELL. WE PUMPED IN 10 BAGS OF CEMENT MIXED W/ 50 GAL OF WATER. WE WAITED 2 HRS., IT ONLY WENT DOWN 1 FOOT. WE FILLED IT BACK THE 1 FOOT, TO THE TOP OF THE WELL, THEN WELDED A FLAT STEEL PLATE ON.				
* NO SURFACE SEAL ON OLD WELL				
* WE DID NOT PUMP ANYTHING TO THE OLD WELL CASING. THE WELL IS INSIDE A BUILDING & WE COULD ONLY SEAL WITHIN 11" W/ OUR PUMP HOSE. THIS WAS OK WITH TOM GALLAGHER OVER THE PHONE.				

Date started 11-7, 1990
Date completed 11-7, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3400	2	13'	4

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter N/A inches Total depth 33'3" feet
inches
inches
Casing record
Weight per foot Thickness .125

Diameter	From	To
6" inches	0 feet	33'3" feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type NONE (OLD WELL)
Depth of seal 6 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation N/A
Size perforation
From N/A feet to N/A feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 19'3" feet below land surface
Flow G.P.M. P.S.I.
Water temperature COLD °F Quality BAD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OGDEN BROS. DRILLING (Contractor)
Address 162 N. BYBEE LN. YERINGTON NV. 89447 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 870
Signed Bill Ogden (By driller performing actual drilling on site or contractor)
Date 11-15-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

STATE ENGINEERS OFFICE
RECEIVED
'90 DEC -3 AM 10:55