

OFFICE USE ONLY
 Log No. 35069
 Permit No. 105
 Basin CARSON VALLEY
 NOTICE OF INTENT NO. 10690

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Indian Hills G.D. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS mica DRIVE
Carson City, NV 89705
 2. LOCATION S 1/4, 8 E 1/4 Sec 7 T. 14 N. R. 20 E Douglas County
 PERMIT NO. 42801 52093 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	2	2
D. G.		2	95	
Sand & GRAVEL		95	123	
COBBLES w/ THIN CLAY Beds				
CLAY interbed w/ gravel		123	138	
COBBLES		138	141	
Sand & Gravel		141	147	
TAN-Brown clay		147	149	
COBBLES & GRAVEL w/ clay		149	151	
Gravel, SAND & clay		151	157	
COBBLES, gravel, rock		157	166	
Brown clay w/ gravel		166	171	
clay w/ gravel		171	189	
white SAND, BIK SAND, round		189	191	
SAND w/ clay		191	198	
COBBLES, gravel, SAND		198	202	
clay & SAND		202	229	
clay & SAND		229	296	
LOOSE SAND		296	301	
SAND & clay		301	329	
HARD SAND		329	331	
SAND & clay		331	346	
GREY clay w/ some sand		346		

8. WELL CONSTRUCTION
 Diameter 15 inches Total depth 340 feet
 _____ inches
 _____ inches
 Casing record _____
 Weight per foot _____ Thickness .250

Diameter	From	To
<u>8</u> inches	<u>7.1</u> feet	<u>350</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 340 feet
 Perforations:
 Type perforation Well Screens
 Size perforation .100 slot
 From 200 feet to 230 feet
 From 250 feet to 280 feet
 From 300 feet to 330 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 5-11, 1988
 Date completed 7-25, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>79</u>	<u>210</u>	<u>24</u>
Plugged by No I # <u>58677</u>			
<u>39.084 4410N</u>			
<u>119.776 4530W NOV 27 (10)</u>			

BAILER TEST
 G.P.M. None Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 90' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality U.K.

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Oasis Drilling, INC Contractor
 Address PO Box 2008 Gardnerville, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0023129
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
 Signed T. Ann By driller performing actual drilling on site or contractor
 Date 10-30-88