

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14666

1. OWNER Truckee Meadows Boys Club ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5405 Mae Ann 10515 Osage
Reno, Nv 89523

2. LOCATION NE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 25 T. 21 N/S R. 18 E Washoe County
 PERMIT NO. 47915 - 47917 86-350-41 Silver Knolls Ranches
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Coarse yellow tan white D.G. with tan clay		0	60	60
White & black sand with brown clay		60	65	5
Green clay & fine sands		65	79	14
Sand layer		79	82	3
Green clay Brown clay mis		82	91	9
Brown clay with coarse sands		91	178	87
T.D. 178 ft				
There is 6 ft of native fill at the bottom of bore hole				
Casing has a cap welded on bottom .188 thick				

8. WELL CONSTRUCTION
 Diameter 10 5/8 inches Total depth 172 feet
 inches
 inches
 Casing record 6 5/8 inch
 Weight per foot 12.92 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>172</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 172 feet

Perforations:
 Type perforation screen - Roscoe/Moss mild steel
 Size perforation .030
 From 142 feet to 152 feet
 From _____ feet to _____ feet

Date started 1/3/91, 19____
 Date completed 1/21/91, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to develop.			
	<u>40</u>		
Test pump - 48 hr constant	<u>132</u>	<u>ft 5 in - 48 hrs</u>	
Recovery after -14 min.	<u>40</u>	<u>ft</u>	

9. WATER LEVEL
 Static water level 40 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
Contractor
 Address 625 Spice Islands Dr Suite L Sparks 89431
Contractor
 Nevada contractor's license number 15291
 issued by the State Contractor's Board.
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources.
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 1/24/91

BAILER TEST

G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours