

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13518

PRINT OR TYPE ONLY

1. OWNER OTTAUZO & YVETTE GREGORIS ADDRESS AT WELL LOCATION 49 PHEASANT
MAILING ADDRESS 49 PHEASANT VERMONT UZREW LAKE WELLS FORD, NV.
WELLS FORD, NV. 89444
2. LOCATION NW 1/4 SW 1/4 Sec 12 T. 11 N. S. R. 23 E. KYON County
PERMIT NO. 07-071-01 Parcel No. 197287 UZREW RANCH EST. LOT #8 Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	5
BROWN CLAY & SAND FILL		5	14	9
COARSE SAND		14	19	5
CLAY & COARSE SAND		19	32	13
BROWN CLAY		32	54	22
COARSE SAND & GRAVEL	X	54	66	12
CLAY & COARSE SAND	X	66	71	5
COARSE SAND & GRAVEL w/ CLAY STRATAS	X	71	79'6"	8'6"

8. WELL CONSTRUCTION
Diameter 8 12 3/8 inches Total depth 80'6" feet
Casing record
Weight per foot _____ Thickness 1.88
Diameter 8 3/8 inches From (+) 1 feet To 80'6" feet
Surface seal: Yes No Type GRAVEL
Depth of seal 50' feet
Gravel packed: Yes No
Gravel packed from 50' feet to 80'6" feet
Perforations:
Type perforation SAWED
Size perforation 3/32" X 3" X 8 ROWS
From 59'6" feet to 79'6" feet
From _____ feet to _____ feet

Date started 11-21, 1990
Date completed 11-26, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
(This area is crossed out with a diagonal line)			

9. WATER LEVEL
Static water level 33' feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OGDEN BROS. DRILLING Contractor YTH & S F W
Address 162 N. BYBEE AVE. NV. 89447 Contractor
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada contractor's driller's number issued by the Division of Water Resources 5704634
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Bill Ogden
By driller performing actual drilling on site or contractor
Date 12-1-90

BAILER TEST
G.P.M. 20 Draw down 10 feet 1/2 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours