CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

DIVISION OF WATER RESOURCES

Log No. 35258
Permit No. 54101
Basin 8-105

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 5373

1. OWNER Sierra Springs Part.
MAILING ADDRESS 100 Central St Reno Nv
ADDRESS AT WELL LOCATION 5 of Carson City 3 mi

2. LOCATION ~~NE~~ NW ¼ Sec. 30 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. 48965 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	60	60
Brown Clay		60	190	130
Clay & Sand		190	210	20
Sand & Gravel		210	240	30
Clay		240	250	10

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 250 feet
Casing record 18 Wall 250 ft
Weight per foot 8" Thickness .188

Diameter	From	To
8 inches	0 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type Cement
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Mill Slot
Size perforation 3/16
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 0 feet below land surface
Flow 60 G.P.M. P.S.I.
Water temperature 60 °F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name [signature] Contractor
Address Contractor
Nevada contractor's license number
Nevada contractor's drillers number #989
Nevada driller's license number #989 Actual Driller
Signed Floyd Sucha Contractor
Date 5-18-85

Date started 10-6, 1985
Date completed 10-13, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

91 FEB 27 PM 4:46 STATE ENGINEER