



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8045

1. OWNER Ron Nailton (Nailton) ADDRESS AT WELL LOCATION Medicine Man
 MAILING ADDRESS _____

2. LOCATION SE 1/4 SE 1/4 Sec. 13 T 20s N/S R 52 E Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 28-631-04 Subdivision Name Charleston Park Ranchos Unit 1 Lot 69

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	25'	25'
calichie		25'	28'	3'
clay		28'	44'	16'
calichie		44'	46'	2'
clay		46'	53'	7'
calichie	WB	53'	56'	3'
clay		56'	69'	13'
calichie	WB	69'	72'	3'
clay		72'	85'	13'
calichie	WB	85'	87'	2'
clay		87'	115'	28'
calichie	WB	115'	117'	2'
clay		117'	122'	5'
calichie	WB	122'	124'	2'
clay		124'	135'	11'
calichie	WB	135'	137'	2'
clay		137'	140'	3'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 0 Feet
140' Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 47' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCr 78 Box 80358 Contractor
Pahrump, Nv. 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1642
 Division of Water Resources, the on-site driller
 Signed Thomas Dun
 By driller performing actual drilling on site or contractor
 Date 7-15-91

Date started 7-5, 1991
 Date completed 7-10, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 JUL 17 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV