


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



35381

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Phill ROGERS ADDRESS AT WELL LOCATION BASIN Rd.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 NE 1/4 Sec. 17 T. 20.2 N/S R. 53 E County DVE  
 PERMIT NO. N/A 36-261-11 CALVEGAS RANCHES LOT 13 UNIT E  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0'	4'	4'
CALICHE		4'	5'	1'
CLAY		5'	36'	31'
CALICHE		36'	39'	3'
CLAY		39'	59'	20'
CALICHE	WB	59'	63'	4'
CLAY		63'	81'	18'
CALICHE	WB	81'	84'	3'
CLAY		84'	92'	8'
CALICHE	WB	92'	96'	4'
CLAY		96'	119'	23'
CALICHE	WB	119'	123'	4'
CLAY		123'	137'	14'
CALICHE	WB	137'	140'	3'

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:  
 Type perforation FACTORY SAWCUT  
 Size perforation 1 1/2 X 3"  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 140' feet to 50' feet

Date started 6-7 1991  
 Date completed 6-10 1991

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 43' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIS DRILLING Contractor  
 Address HCR 98 BOX 80358 Contractor  
PAHRUMP, NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Dianne Brown  
 By driller performing actual drilling on site or contractor  
 Date 6-11-91

RECEIVED

JUN 17 1991

Div. of Water Resources  
 Branch Office - Las Vegas, NV