WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35393
Permit No.
Basin

NOTICE OF INTENT NO. 8011

1. OWNER Bob Tomaro
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SW ¼ Sec. 29 T. 20S N/S R. 53 E. NYE County
PERMIT NO. N/A (Issued by Water Resources) 40-251-07 (Parcel No.) Calvada Unit 5 Blk 4 Lot 7 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	5'	5'
Caliche		5'	6'	1'
Clay		6'	13'	7'
Caliche		13'	23'	10'
Clay		23'	44'	21'
Caliche		44'	47'	3'
Clay		47'	60'	13'
Caliche	WB	60'	64'	4'
Clay		64'	81'	17'
Caliche	WB	81'	86'	5'
Clay		86'	94'	8'
Caliche	WB	94'	97'	3'
Clay		97'	108'	11'
Caliche	WB	108'	111'	3'
Clay		111'	122'	10'
Caliche	WB	122'	127'	4'
Clay		127'	133'	6'
Caliche	WB	133'	136'	3'
Clay		136'	140'	4'

RECEIVED
JUN 17 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-5, 1991
Date completed 6-10, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
Type perforation Factory sawcut
Size perforation 1/8 X 3"
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140' feet to 50' feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed Dominic Brown
By driller performing actual drilling on site or contractor
Date 6-11-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627