


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.140



Log No. 35421
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 8049

1. OWNER Richard Paganelli ADDRESS AT WELL LOCATION Heritage St.
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NW 1/4 Sec. 11 T. 21s. N/S R. 53 E. Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 44-391-15 Red Rock Est. Lot 28' Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	22'	22'
calichie		22'	28'	6'
clay		28'	36'	8'
calichie		36'	38'	2'
clay		38'	62'	24'
calichie	WB	62'	82'	20'
clay		82'	100'	18'
calichie	WB	100'	103'	3'
clay		103'	115'	12'
calichie	WB	115'	120'	5'
clay		120'	125'	5'
calichie	Wb	125'	135'	10'
clay		135'	140'	5'

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 0' Feet 140' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV. 89041
 Nevada contractor's license number 30880 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1642 Division of Water Resources, the on-site driller.
 Signed Thomas Dun
 By driller performing actual drilling on site or contractor
 Date 7-22-91

Date started 7-18, 1991
 Date completed 7-20, 1991

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

RECEIVED

JUL 29 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV