

OFFICE USE ONLY
 Log No. 33471
 Permit No. 54290
 Basin 212
 NOTICE OF INTENT NO. 3306

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Gerry shlesinger ADDRESS AT WELL LOCATION Windmill & Rancho Destino
 MAILING ADDRESS 1860 Sage Ave.
Los Osos, Ca. 93402
 2. LOCATION SE 1/4 NW 1/4 Sec 16 T 22 N/S R 60.61 E Clark County
 PERMIT NO. 54290 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand		0	4	4
white silt		4	10	6
silt sand clay		10	26	16
silt & gravel congl.		26	35	9
silt clay & gravel		35	56	21
brown clay some gravel		56	116	60
partially cemented		116	120	4
clay sand & gravel		120	160	40
sand & gravel		160	165	5
clay		165	185	20
sand & gravel	X	185	231	46
clay sand & gravel		231	252	21
gravel		252	313	61
cemented congl.		313	380	67
clay sand & gravel		380	405	25

8. WELL CONSTRUCTION
 Depth Drilled 405 Feet Depth Cased 405 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches +1 Feet 405 Feet
 To 10 Inches + Feet + Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	405

Perforations:
 Type perforation Torch
 Size perforation 3/16 x 6 x 4 around
 From 200 feet to 405 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 62 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From feet to feet

RECEIVED

JUN 21 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 6-7, 1991
 Date completed 6-11, 1991

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
30	?	2	

9. WATER LEVEL
 Static water level 155 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Allen Drilling, Inc Contractor
 Address 4847 So. Valley View Blvd. Contractor
Las Vegas, Nev. 89103
 Nevada contractor's license number issued by the State Contractor's Board 0018916-0018917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
 Signed Donald L. Wall
 By driller performing actual drilling on site or contractor
 Date 6-12-91