




Log No. 35485  
 Permit No. \_\_\_\_\_  
 Basin 212



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 8584

PRINT OR TYPE ONLY

1. OWNER K. D. Dorman ADDRESS AT WELL LOCATION 9241 McLeod  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NW 1/4 Sec. 24 T. 22 N. 61 E CLARK County  
 PERMIT NO. NA-57543 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>VOLCANIC boulders</u>		<u>0</u>	<u>160</u>	<u>160</u>
<u>Clinders</u>	<u>x</u>	<u>160</u>	<u>240</u>	<u>80</u>
<u>Red Clay</u>		<u>240</u>	<u>280</u>	<u>40</u>
<u>Consolidated gravel</u>	<u>x</u>	<u>280</u>	<u>296</u>	<u>16</u>

Note  
Corrected  
Property Description  
S.E. 1/4 in place  
of SW. 1/4

**RECEIVED**  
 JUN 24 1991

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 9-21, 1990  
 Date completed 9-25, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR TEST</u>	<u>900 GPM</u>	<u>@ 250 PSI</u>	
<u>359 RPM</u>	<u>@ 296'</u>		

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 296 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness .188  
 Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
8 inches + 1 feet 296 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 296 feet  
 Perforations:  
 Type perforation Torch  
 Size perforation 1/4 x 10"  
 From 180 feet to 240 feet  
 From 280 feet to 296 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 140' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Dean Mitchell Contractor  
 Address 630 RATTIG AV. N. V. NEV. 89134 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 27030  
 Nevada contractor's driller's number issued by the Division of Water Resources 1475  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475  
 Signed Dean Mitchell  
 By driller performing actual drilling on site or contractor  
 Date 9-25-90