



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6145

1. OWNER ELDON HUFFARD ADDRESS AT WELL LOCATION OFF QUARTZ AVE. NEAR MOHAVE  
 MAILING ADDRESS 4789 EVERMAN DR. LAS VEGAS NEV. 89122

2. LOCATION N.W. 1/4 NE 1/4 Sec 6 T. 25 N. 57 E. CLARK County  
 PERMIT NO. 594-330-08A Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material            | Water Strata | From | To  | Thick-ness |
|---------------------|--------------|------|-----|------------|
| SANDY LOAM          |              | 0    | 2   | 2          |
| CALICHE             |              | 2    | 14  | 12         |
| BROWN CLAY          |              | 14   | 48  | 34         |
| CALICHE             | WTR          | 48   | 51  | 3          |
| WHITE CLAY          |              | 51   | 57  | 6          |
| CORAL               |              | 57   | 68  | 11         |
| GREY CLAY           |              | 68   | 88  | 20         |
| CALICHE             | WTR          | 88   | 90  | 2          |
| LIGHT BRN CLAY CONG |              | 90   | 115 | 25         |
| CALICHE             | WTR          | 115  | 118 | 3          |
| CONS BRN CLAY       |              | 118  | 125 | 7          |

8. WELL CONSTRUCTION

Diameter 14 inches Total depth 125 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches

Casing record STEEL  
 Weight per foot 18.7 Thickness 1.88

| Diameter           | From          | To              |
|--------------------|---------------|-----------------|
| <u>8.58</u> inches | <u>0</u> feet | <u>125</u> feet |
| _____ inches       | _____ feet    | _____ feet      |
| _____ inches       | _____ feet    | _____ feet      |
| _____ inches       | _____ feet    | _____ feet      |
| _____ inches       | _____ feet    | _____ feet      |
| _____ inches       | _____ feet    | _____ feet      |

Surface seal: Yes  No  Type CEMENT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 125 feet

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1/8 X 4  
 From 105 feet to 125 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 MAY 28 1991  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started MAY 7 1991  
 Date completed MAY 10 1991

7. WELL TEST DATA

| Pump RPM    | G.P.M.    | Draw Down | After Hours Pump |
|-------------|-----------|-----------|------------------|
| <u>3450</u> | <u>25</u> | <u>2</u>  | <u>2</u>         |
| _____       | _____     | _____     | _____            |
| _____       | _____     | _____     | _____            |

BAILER TEST

| G.P.M. | Draw down | feet  | hours |
|--------|-----------|-------|-------|
| _____  | _____     | _____ | _____ |
| _____  | _____     | _____ | _____ |
| _____  | _____     | _____ | _____ |

9. WATER LEVEL  
 Static water level 43 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 67 °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name RCBB INC. Contractor  
 Address 1701 W. CHINA BLVD. LAS VEGAS, NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 020301  
 Nevada contractor's driller's number issued by the Division of Water Resources 1352  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352  
 Signed Robert Sawicki  
 By driller performing actual drilling on site or contractor  
 Date May 20-91