

OFFICE USE ONLY
 Log No. 35505
 Permit No. 55174T
 Basin 87
 15427

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15427

1. OWNER Westpac Utilities ADDRESS AT WELL LOCATION Idlewild
 MAILING ADDRESS P.O. Box 30028 1230 IDLEWILD DR. Idlewild Park
Reno, NV 89520-3028 Reno, Nev. Reno, NV
 2. LOCATION NE 1/4 NE 1/4 Sec. 15 T. 19 N R. 19 E. Washoe County
 PERMIT NO. 55436T 10-15126 Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders		0	50	50
Sand & Gravel		50	86	36
Course Sand & Gravel				
Some Rock		86	116	30
Sand & Gravel				
Course Gravel		116	136	20
Course Gravel	X	136	156	20
Course Sand & Gravel	X	156	196	40
Course Rock		196	256	60
Course Sand & Gravel	X	256	296	40
Sand & Gravel	X	296	376	80
Course Sand & Gravel	X	376	456	80
Cement Seal		430	456	26

8. WELL CONSTRUCTION
 Diameter 42 inches Total depth 270 feet
30 inches From 0 to 177
16 inches From 0 to 456
 Casing record: 30" X 375 W & 16" X 375 W
 Weight per foot..... Thickness.....

Diameter	From	To
<u>30</u> inches	<u>0</u> feet	<u>177</u> feet
<u>16</u> inches	<u>0</u> feet	<u>456</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

 Surface seal: Yes No Type Neat Cement
 Depth of seal..... 175 feet
 Gravel packed: Yes No
 Gravel packed from..... 0 feet to..... 456 feet
 Perforations:
 Type perforation..... Houston Screen
 Size perforation..... 245 & 240 Slot
 From..... 180 feet to..... 230 feet .040
 From..... 230 feet to..... 240 Blank feet .375
 From..... 240 feet to..... 370 feet .040
 From..... 370 feet to..... 380 Blank feet .375
 From..... 380 feet to..... 420 feet .375
420 430 Blank .375

Date started March 28, 1991
 Date completed June 6, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>2000</u>	<u>102</u>	<u>48</u>

BAILER TEST
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours

9. WATER LEVEL
 Static water level..... 120 feet below land surface
 Flow..... G.P.M. P.S.I.
 Water temperature Cold °F Quality.....

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Address..... P.O. Box 592 Wmca., NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada contractor's driller's number issued by the Division of Water Resources..... 1154
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller..... 1714
 Signed.....
 By driller performing actual drilling on site or contractor
 Date 7/15/91