WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 35527
Permit No.
Basin

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 8424

1. OWNER Riverside Resorts, Inc. C/O The Planning Group
MAILING ADDRESS P.O. Box 69
Bullhead City, AZ 86430

ADDRESS AT WELL LOCATION Riverside Resort
1650 Casino Dr.
Laughlin, NV 89029

2. LOCATION ¼ NW ¼ Sec. 13 T. 32 N/S R. 68 E. Clark County

PERMIT NO. MO-2095 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly Sand		0'	1'	1'
Sandy Clay		1'	3'	2'
Silty Sand		3'	5'	2'
Sandy Clay		5'	7'	2'
Silty Sand		7'	12'	5'
Sandy Clay		12'	15'	3'
Silty Sand		15'	20'	5'
Gravelly Sand Cobbles		20'	30'	–

RECEIVED
NOV 18 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-4, 1991
Date completed 10-4, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours
G.P.M. Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 4 inches Total depth 30 feet
inches
inches
Casing record PVC - Schedule 40
Weight per foot N/A Thickness N/A

Diameter	From	To
4 inches	0 feet	30 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement-Bentonite
Depth of seal 12 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 12 feet to 30 feet

Perforations:
Type perforation Machine Slotted-PVC-Sch. 40
Size perforation 0.020 inch
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level ≈ 21 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Poor

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WT Environmental Consultants (Contractor)
Address 3611 W. Tompkins Ave. Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0033048
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-11-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627