

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8302

1. OWNER Bill Moore ADDRESS AT WELL LOCATION Ambler
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec 19 T 19S N/S R 53 E Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 29-442-12 Subdivision Name Valley View Acres Lot 232

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay		0'	24'	24'
caliche		24'	26'	2'
clay		26'	36'	10'
caliche		36'	37'	1'
clay		37'	41'	4'
caliche		41'	44'	3'
clay		44'	56'	12'
caliche	WB	56'	59'	3'
clay		59'	65'	6'
caliche	WB	65'	66'	1'
clay		66'	81'	15'
caliche	WB	81'	84'	3'
clay		84'	95'	11'
caliche	WB	95'	97'	2'
clay		97'	100'	3'

8. WELL CONSTRUCTION
 Depth Drilled 100' Feet Depth Cased 100' Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 0' Feet
100' Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10.78	.156	0'	100'

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From 100' feet to 80' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100' feet to 50' feet

9. WATER LEVEL
 Static water level 44 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, Nv. 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dun
 By driller performing actual drilling on site or contractor
 Date 8-19-91

Date started 8-9, 1991
 Date completed 8-17, 1991

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 AUG 22 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV

