


WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



35581

8218

1. OWNER Texas Refining + Marketing Inc

ADDRESS AT WELL LOCATION Texas Terminal

MAILING ADDRESS 10 Universal City Plaza

5049 -13 Sloan Lane

UNIVERSITY CITY CA 91608

N. Las Vegas Nevada

2. LOCATION NW 1/4 NW 1/4 Sec 34 T. 19

N/S R 62 E

Clark

County

PERMIT NO. MD 2075

Parcel No.

Subdivision Name

3. WORK PERFORMED
 New Well
 Replace
 Recondition
 Deepen
 Abandon
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY SILT		0	20	20'
CAULKITE		20	22	2'
CLAYE SILT		22	85	63
SANDY CLAY		85	91	6
CLAYE SILT		91	102	11
SANDY/Silty clay		102	125	23

8. WELL CONSTRUCTION

Depth Drilled 126 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 125 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"				

Perforations: Type perforation 0.010 factory slotted
 Size perforation 125 feet to 85 feet

From 125 feet to 85 feet
 From 85 feet to 91 feet
 From 91 feet to 102 feet
 From 102 feet to 125 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

RECEIVED

SEP 17 1991

Div. of Water Resources
 Las Vegas, NV

9. WATER LEVEL
 Static water level 92 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carl Lyons Rayne Environmental
 Contractor
 Address 9002 South Hardy Drive
 Contractor

Date Tempe AZ

Nevada contractor's license number
 Issued by the State Contractor's Board.

Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller
 Signed Rayne Environmental
 By driller performing actual drilling on site or contractor
 Date 9/17/91

7. WELL TEST DATA

Date started 9-2-91 19
 Date completed 9-2-91 19

TEST METHOD: Bailor Pump Air Lift
 G.P.M. (Feet Below Static) Time (Hours)