

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

License No. 35286
 Permit No. 3343
 Basin 1
 NOTICE OF INTENT NO. 3343

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. OWNER REBEL OIL COMPANY ADDRESS AT WELL LOCATION 5054 W. STAN LANE
 MAILING ADDRESS 1900 E. SAHARA AV LAS VEGAS, NV 89104
 2. LOCATION NW 1/4 SW 1/4 Sec. 34 T 19 NR. 62 E CLARK County
 PERMIT NO. MO 2060 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock

4. Domestic Municipal/Industrial

5. WELL TYPE
 Cable Rotary Other _____

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thickness
SILTY GRAVEL		0'	5'	5'
SILTY SAND		5'	10'	5'
SILTY GRAVEL		10'	14'	4'
CLAYEY SILT		14'	16'	2'
CALICHE		16'	21'	5'
SILTY CLAY		21'	24'	3'
SILTY GRAVEL		24'	30'	6'
SILTY CLAY		30'	48'	18'
CALICHE		48'	55'	7'
SILTY CLAY		55'	61'	6'
CALICHE		61'	65'	4'
CLAYEY SILT		65'	67'	2'
SILTY SAND		67'	76'	9'
SANDY CLAY		76'	88'	12'
SILTY SAND		88'	99'	11'
SILTY CLAY		99'	125'	26'

8. WELL CONSTRUCTION
 Total Depth 125 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
6 Inches _____ 0 Feet 125 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>			<u>0</u>	<u>125</u>

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal _____ 70'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ 70 Feet to _____ 125 Feet

9. WATER LEVEL
 Static water level _____ 102.71 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DON WILSON Contractor
 Address 4670 S POLARIS AV
LAS VEGAS, NV 89103 Contractor

Nevada contractor's license number _____
 Issued by the State Contractor's Board _____
 Nevada contractor's driller's number _____
 Issued by the Division of Water Resources _____

Nevada driller's license number issued by the Division of Water Resources, the on-site driller _____ M1589
 Signed Don Wilson
 By driller performing actual drilling on site or contractor _____
 Date _____

7. WELL TEST DATA
 TEST METHOD: Bailor Pump Air Lift
 G.P.M. _____ Draw Down (Feet Below Static) _____ Time (Hours) _____

Date started JUNE 12 1991
 Date completed JUNE 12 1991

Div. of Water Resources
 Branch Office - Las Vegas, NV



RECEIVED
 SEP 27 1991