

15

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 35596
Permit No. 212
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Atlantia Design ADDRESS AT WELL LOCATION NWC Carson
 MAILING ADDRESS 3260 S. Industrial Rd. 14th City of Las Vegas
Las Vegas NV 89109

2. LOCATION NW 1/4 NE 1/4 Sec. 34 T 20 N R 61 E Clark County

PERMIT NO. ME 2076 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary
 Other _____

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thick-ness
FILL		0	1/2	1/2
SILTY clay w/ calg.		1/2	2 1/2	2
sandy clay w/ calg.		2 1/2	7	4 1/2
Silty clay w/ calg.		7	9	2
Sandy clay w/ calg.		9	11	2
Caliche		11	12 1/2	1 1/2
Sandy clay w/ calg.		12 1/2	17	4 1/2
Caliche		17	18	1
Silty clay w/ calg.		18	20	2
Caliche		20	22	2
Sandy clay w/ calg.		22	26	4
Clayey sand w/ calg.		26	28	2

8. WELL CONSTRUCTION

Total Depth 28 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
6	0	2.5	Feet
			Feet
			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40 pipe	0	28

Surface Seal: Yes No Seal Type:
 Depth of Seal 4 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 6 Feet to 28 Feet

9. WATER LEVEL

Static water level 9.70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name _____ Contractor
 Address _____ Contractor

Date started 7-17, 1991
 Date completed 7-17, 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>NA</u>	

Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1761
 Signed Gregory A. Vogt
 By driller performing actual drilling on site or contractor
 Date 8/13/91

RECEIVED

SEP 24 1991

Div. of Water Resources
French Crater - Las Vegas, NV