

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Atlantia Design ADDRESS AT WELL LOCATION NWC Carson  
 MAILING ADDRESS 3260 Industrial Rd. 4th St. City of Las Vegas  
Las Vegas, NV 89109

2. LOCATION NW 1/4 NE 1/4 Sec 34 T. 20 N. R. 61 E Clark County  
 PERMIT NO. MO-2032 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  
 Other \_\_\_\_\_

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thick-ness
FILL		0	1/2	1/2
SANDY CLAY		1/2	3 1/2	3
SILT CLAY		3 1/2	8 1/2	5
CALICHE		8 1/2	9	1/2
SILT CLAY w/ calgo.	10-12	9	12	3
CALICHE		12	14	2
SANDY CLAY		14	15 1/2	1 1/2
CALICHE		15 1/2	16	1/2
SILT CLAY w/ calgo.		16	26 1/2	11 1/2

8. WELL CONSTRUCTION  
 Total Depth 26 1/2 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
6 1/2 Inches \_\_\_\_\_ Feet 26 1/2 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40 PVC		

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 2 1/2  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 4 1/2 Feet to 26 1/2 Feet

9. WATER LEVEL  
 Static water level 9.90 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name \_\_\_\_\_ Contractor  
 Address \_\_\_\_\_ Contractor

Date started 7-19, 1991  
 Date completed 7-19, 1991

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA	NA	

Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-9-91

RECEIVED  
 SEP 24 1991

Div. of Water Resources  
 Branch Office - Las Vegas, NV