

Log No. 35079
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 8333

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Lee Karczeski ADDRESS AT WELL LOCATION Oakridge
 MAILING ADDRESS _____

2. LOCATION NE 1/4 SW 1/4 Sec. 12 T. 21 N/S R. 53 E. Nye County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 44-551-21 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
caliche		0'	3'	3'
clay		3'	11'	8'
caliche		11'	14'	3'
clay		14'	20'	6'
caliche		20'	36'	16'
clay		36'	42'	6'
caliche		42'	54'	12'
clay		54'	59'	5'
caliche	WB	59'	64'	5'
clay		64'	73'	9'
caliche	WB	73'	79'	6'
clay		79'	84'	5'
caliche	WB	84'	88'	4'
clay		88'	94'	6'
caliche	WB	94'	97'	3'
clay		97'	106'	9'
caliche	WB	106'	109'	3'
clay		109'	115'	6'
caliche	WB	115'	121'	6'
clay		121'	131'	10'
caliche	WB	131'	134'	3'
clay		134'	140'	6'

RECEIVED
 OCT 03 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
 Depth Drilled 140' Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 1/2 Inches 0' Feet 140' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:
 Type perforation factory sawcut
 Size perforation 1/8 x 3
 From 140 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140' feet to 50' feet

Date started 9-24 1991
 Date completed 9-24 1991

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 47 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump, NV, 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 9-30-91