

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
Log No. 35695  
Permit No. 162  
Basin 162

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 8299

1. OWNER James H. Carroll ADDRESS AT WELL LOCATION Piute Rd.  
MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 NW 1/4 Sec. 20 T. 21s N/S R. 54 E Nye County  
PERMIT NO. N/A Issued by Water Resources | 45-282-17 Parcel No. | Greensaddle Ranch Lot 128 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0'	13'	13'
calichie		13'	18'	5'
clay		18'	45'	27'
calichie		45'	51'	6'
clay		51'	68'	17'
calichie		68'	70'	2'
clay		70'	79'	9'
calichie	WB	79'	82'	3'
clay		82'	95'	13'
calichie	WB	95'	96'	1'
clay		96'	109'	13'
calichie	WB	109'	113'	4'
clay		113'	123'	10'
calichie	WB	123'	137'	14'
clay		137'	140'	3'

8. WELL CONSTRUCTION  
Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)  
From To  
12 1/2 Inches 0' Feet 140' Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:  
Type perforation factory sawcut  
Size perforation 1/8 x 3  
From 140 feet to 120 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 140' feet to 50' feet

RECEIVED

JUL 30 1991

Div. of Water Resources  
Branch Office - Las Vegas, NV

Date started 7-25, 1991  
Date completed \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
Static water level 59 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Contractor  
Address HCR 78 Box 80358 Contractor  
Pahrump, Nv. 89041

Nevada contractor's license number 30880 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Davis  
By driller performing actual drilling on site or contractor  
Date 7-25-91

