WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

in Book

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35697
Permit No.
Basin 162

NOTICE OF INTENT NO. 8055

1. OWNER J.A Rastall
MAILING ADDRESS
ADDRESS AT WELL LOCATION Fox St.

2. LOCATION SE ¼ NE ¼ Sec. 29 T. 21S N/S R. 54 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 45-401-26 (Parcel No.) | Fox Hollow Lot 58 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	3'	3'
Calichie		3'	4'	1'
Clay		4'	18'	14'
Calichie		18'	20'	3'
Clay		21'	34'	13'
Calichie		34'	42'	8'
Clay		42'	50'	8'
Calichie		50'	54	4'
Clay		54'	67'	13'
Calichie	WB	67'	82'	15'
Clay		82'	97'	15'
Calichie	WB	97'	101'	4'
Clay		101'	109'	8'
Calichie	WB	109'	116'	7'
Clay		116'	127'	11'
Calichie	WB	127'	134'	7'
Clay		134'	156'	22'
Calichie	WB	156'	163'	7'
Clay		163'	172'	9'
Calichie	WB	172'	176'	4'
Clay		176'	180'	4'

RECEIVED
OCT 29 1991
Div. of Water Resources
Branch Office-Las Vegas, NV

Date started 10-17, 19 91
Date completed 10-22, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12 1/4	0'	180'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	180'

Perforations:
Type perforation factory sawcut
Size perforation 1/8 x 3
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 180' feet to 50' feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80358
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 10-24-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627